



PLAN VIEW



SECTION A-A



ELEVATION

NOTES:

1. ENERGY DISSIPATION PAD PROVIDED AS STABILIZED ENTRANCE TO BIORETENTION SYSTEM. ROCK SHALL BE PLACED IN IRREGULAR PATTERN USING NON-UNIFORM SIZES TO PREVENT PREFERENTIAL FLOW PATHS. INCREASE ENERGY DISSIPATION, AND TO LIMIT THE SURFACE AREA OF EXPOSED MORTAR. ALTERNATIVE PRE-TREATMENT SOLUTIONS WILL BE CONSIDERED.
2. WHERE NECESSARY, EXTEND GUTTER TO 2.5' WIDTH TO ACCOMMODATE TRASH CONTAINER PLACEMENT.
3. ROCK AND MORTAR INLET PROTECTION SHALL EXTEND ACROSS BOTTOM OF BIORETENTION TO OPPOSITE TOE OF SLOPE, OR 2' MINIMUM. FINISH GRADE OF MORTARED BOTTOM SHALL BE AT LEAST 3" BELOW ADJACENT BIORETENTION BOTTOM ELEVATION TO PROVIDE SEDIMENT STORAGE.
4. ATTACHMENT OF 30 MIL IMPERMEABLE LINER TO CONCRETE CURBS (USING CONCRETE ANCHORS SPACED AT MAXIMUM 18" O. C. AND BATTEN STRIPS) SHALL BE DONE IN ACCORDANCE WITH ASTM 6497.

CITY OF RALEIGH STANDARD DETAIL		
REVISIONS	DATE: 8/2020	NOT TO SCALE
CURB-CUT INLET (TAPERED STREET RELIEF)		
GSI-03.1		