

NOTES:

1. SELECTION OF BUMP-OUT BIORETENTION TYPE AND LOCATION DEPENDS ON ROADWAY DESIGN CONDITIONS AND ARE ASSUMED TO BE INSTALLED IN CONJUNCTION WITH RETROFIT/STREET IMPROVEMENT PROJECTS.
2. IN ALL CASES, BUMP-OUTS MUST MAINTAIN REQUIRED GUTTER SPREAD TO SAFELY PASS OVERFLOW FROM THE 2-YR STORM (I.E., PONDED WATER LESS THAN 1/2 LANE WIDTH FROM EDGE OF CURB).
3. WHERE NECESSARY, RISER STRUCTURES SIZED FOR THE 2-YR STORM SHALL BE LOCATED WITHIN BUMP-OUT BIORETENTION. ALL BIORETENTION BUMP-OUTS SHALL BE DESIGNED TO BYPASS STORMS LARGER THAN THE 2-YR EVENT.
4. ALL BIORETENTION AND PERMEABLE PAVEMENT UNDERDRAINS, IF REQUIRED, SHALL CONNECT TO STORM DRAIN OR OTHER DRAINAGE FEATURE ACCEPTABLE TO THE CITY ENGINEER.
5. ALL FEATURES, INCLUDING VEGETATION, INTERGRATED INTO BUMP-OUT BIORETENTION SHALL MEET SIGHT DISTANCE REQUIREMENTS PER STREET DESIGN MANUAL AND RECOMMENDED PLANT SPECIES IN THE NC DEQ STORMWATER BMP MANUAL AND CITY OF RALEIGH STORMWATER DESIGN MANUAL.
6. ROADWAY FEATURES AND PAVEMENT MARKINGS ARE FOR REFERENCE ONLY. ACTUAL DIMENSIONS AND MARKINGS SHALL CONFORM TO THE CITY OF RALEIGH STREET DESIGN MANUAL.

CITY OF RALEIGH STANDARD DETAIL		
<i>REVISIONS</i>	<i>DATE: 8/2020</i>	<i>NOT TO SCALE</i>
	GREEN INFRASTRUCTURE GENERAL NOTES	
	GSI-06.2	