



NOTES:
 ALL PIPE UNDERDRAINS ARE TO EXIT INTO DRAINAGE STRUCTURES SUCH AS CATCH BASINS OR JUNCTION BOXES. IF STRUCTURE IS NOT AVAILABLE, SPECIAL EXIT REQUIREMENTS WILL APPLY IN ACCORDANCE WITH THE DIRECTION OF ENGINEERING SERVICES DIRECTOR OR HIS/HER DESIGNEE.

CITY OF RALEIGH		
STANDARD DETAIL		
REVISIONS	DATE: 8/2020	NOT TO SCALE
	PIPE UNDERDRAIN DETAIL	
	SW-10.11	