



INSTALLATION NOTES:

1. HARDWARE CLOTH AND GRAVEL SHOULD OVERLAY THE SILT FENCE A MINIMUM OF 12 INCHES.
2. STONE OUTLETS SHOULD BE PLACED ON LOW ELEVATION AREAS OF SILT FENCE AND BASED ON FIELD CONDITIONS.

MAINTENANCE NOTES:

1. MEASURES SHALL BE INSPECTED AT LEAST ONCE A WEEK OR IMMEDIATELY AFTER EACH RAINFALL OF 1.0 INCH OR GREATER. MAKE ANY REQUIRED REPAIRS IMMEDIATELY.
2. KEEP HARDWARE CLOTH FREE OF DEBRIS TO PROVIDE ADEQUATE FLOW.
3. FRESHEN STONE WHEN SEDIMENT ACCUMULATION EXCEEDS 6 INCHES.
4. REMOVE SEDIMENT AND REPLACE WITH NEW STONE WHEN HALF OF THE STONE OUTLET IS COVERED.
5. REPLACE STONE AS NEEDED TO FACILITATE DEWATERING.

CITY OF RALEIGH STANDARD DETAIL		
REVISIONS	DATE: 9/2024	NOT TO SCALE
		STANDARD SILT FENCE OUTLET
		SW-20.04