



INSTALLATION NOTES:

1. ACTUAL LAYOUT TO BE DETERMINED IN THE FIELD.
2. CONCRETE WASHOUT SIGN SHALL BE INSTALLED WITHIN 30 FEET OF THE TEMPORARY CONCRETE WASHOUT FACILITY.
3. MATERIALS USED TO CONSTRUCT TEMPORARY CONCRETE WASHOUT FACILITIES SHALL BE REMOVED FROM THE SITE OF THE WORK AND DISPOSED OF OR RECYCLED.
4. HOLES, DEPRESSIONS, OR OTHER GROUND DISTURBANCE CAUSED BY THE REMOVAL OF THE TEMPORARY CONCRETE WASHOUT FACILITIES SHALL BE BACKFILLED, REPAIRED AND STABILIZED TO PREVENT EROSION.
5. MUST BE LOCATED AT LEAST 50 FEET FROM INLETS/WATERWAYS UNLESS THERE IS NO OTHER PRACTICAL ALTERNATIVE.

MAINTENANCE NOTES:

1. MEASURES SHALL BE INSPECTED AT LEAST ONCE A WEEK OR IMMEDIATELY AFTER EACH RAINFALL OF 1.0 INCH OR GREATER. MAKE ANY REQUIRED REPAIRS IMMEDIATELY.
2. REMOVE LIQUID AND/OR SOLID MATERIAL WHEN IT REACHES 75% CAPACITY TO LIMIT OVERFLOW EVENTS.
3. REPLACE STRUCTURAL COMPONENTS AS NEEDED.

CITY OF RALEIGH	
STANDARD DETAIL	
REVISIONS	DATE: 9/2024
	NOT TO SCALE
CONCRETE WASHOUT	
SW-20.27	