



NOTES:

1. SEE STANDARD DETAIL T-10.26.1 FOR CURB AND GUTTER DETAILS.
2. EXPANSION MATERIAL SHALL EXTEND THE FULL DEPTH OF THE CONCRETE.
3. ALL CONCRETE SHALL BE 3000 PSI (MIN.).

CITY OF RALEIGH		
STANDARD DETAIL		
REVISIONS	DATE: 8/2020	NOT TO SCALE
	DRIVEWAY FOR VALLEY TYPE CURB & GUTTER	
T-10.02		