



FIRE PUMP ISOMETRIC

N.T.S.

NOTES:
HYDROSTATIC TEST ALL PIPING PER NFPA 13.
PUMP TEST HEADER IS REQUIRED.

CITY OF RALEIGH FIRE DEPARTMENT
FIRE PROTECTION DIVISION
310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:
FIRE PUMP ISOMETRIC

REVISIONS:
5-1-2017

DATE:
5/1/06

DRAWING NO.
FP-7