



CITY OF RALEIGH

2023 Perfluorinated Compound Data

units: ng/L

Perfluorinated Compounds Contaminant	EPA MRL	1/19/2023				Health Advisory Levels
		EMJWTP		DEBWTP		
		Finished	Raw	Finished	Raw	
GenX	5.0	<5.0	<5.0	<5.0	<5.0	10
Perfluorobutanesulfonic acid (PFBS)	3.0	3.1	3.4	<3.0	<3.0	2000
Perfluorooctanesulfonic acid (PFOS)	4.0	<4.0	5.7	<4.0	<4.0	0.02
Perfluorooctanoic acid (PFOA)	4.0	<4.0	<4.0	<4.0	<4.0	0.004

MRL-Minimum Reporting Level