



## EM Johnson WTP Monthly Finished Water Quality Report April 2025

Parameter	Plant Tap	Primary MCL **	Secondary MCL **
Temperature, °C	22.9		
Color, units	0.6		15
pH, units	8.40		6.5 - 8.5
Free Carbon Dioxide, mg/l	0.20		
Total Alkalinity, mg/l as CaCO <sub>3</sub>	24.2		
Total Hardness, mg/l as CaCO <sub>3</sub>	25.1		
Specific Conductivity, uS/cm	192		
Iron, mg/l	<0.10		0.3
Manganese, mg/l	<0.01		0.05
Fluoride, mg/l	0.74	4	2
Chloride, mg/l	13.7		250
Ammonia, mg/l as N	0.590		
Nitrate, mg/l as N	0.054	10	
Silica, mg/l as SiO <sub>3</sub>	6.60		
Total Coliform Bacteria*	Absent	0	
E. Coli	Absent	0	
Total Trihalomethanes, mg/l	0.011	0.080	

\* In 95% of samples collected

\*\*MCL = Maximum Contaminant Level

\*\*\*Chlorine Burnout, no ammonia added

Certified By: Martesa Webb

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604

---

*Raleigh Water: Serving the people of Garner, Knightdale, Raleigh, Rolesville,  
Wake Forest, Wendell, and Zebulon areas.*

One Exchange Plaza Building | 1 Exchange Plaza | Suite 600 | Raleigh, North Carolina 27601  
City of Raleigh (mailing address) | Post Office Box 590 | Raleigh, North Carolina 27602-0590

## EM Johnson WTP Finished Water Quality Report 2025 Plant Tap Summary

Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Average
Temperature, °C	12.2	14.0	17.2	22.9									16.6
Color, units	1.3	0.0	0.0	0.6									0.5
pH, units	8.4	8.4	8.3	8.4									8.4
Free Carbon Dioxide, mg/l	0.17	0.17	0.23	0.20									0.19
Total Alkalinity, mg/l as CaCO <sub>3</sub>	21.3	21.0	24.7	24.2									22.8
Total Hardness, mg/l as CaCO <sub>3</sub>	22.8	23.4	25.7	25.1									24.3
Specific Conductivity, uS/cm	176	176.5	194.1	192									185
Iron, mg/l	<0.10	<0.10	<0.10	<0.10									<0.10
Manganese, mg/l	<0.01	<0.01	<0.01	<0.01									<0.01
Fluoride, mg/l	0.62	0.42	0.73	0.74									0.63
Chloride, mg/l	10.0	10.2	13.0	13.7									11.7
Ammonia, mg/l as N	0.63	0.50	***	0.59									0.57
Nitrate, mg/l as N	0.22	0.22	0.15	0.05									0.16
Silica, mg/l as SiO <sub>3</sub>	9.58	7.90	7.30	6.60									7.85
Total Coliform Bacteria	Absent	Absent	Absent	Absent									Absent
E. Coli	Absent	Absent	Absent	Absent									Absent
Total Trihalomethanes, mg/l	0.011	0.013	0.010	0.0110									0.011

\*\*\*Chlorine Burnout, no ammonia added

Certified By: Martesa Webb

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604