



PLAN VIEW

CAST DATE



BOTTOM VIEW



SECTION VIEW

- NOTE 1 - "WATER" LETTERING MUST BE 1" RAISED (RECESSED FLUSH)
- NOTE 2 - VALVE COVER SHALL BE DOMESTICALLY CAST.
- NOTE 3 - COVER MUST HAVE A MINIMUM WEIGHT OF 25 POUNDS.
- NOTE 4 - COVER MUST BE CLASS 35 OR GREATER.
- NOTE 5 - COVER MUST MEET OR EXCEED AASHTO H-20 LOAD REQUIREMENTS.

CITY OF RALEIGH  
DEPARTMENT OF PUBLIC UTILITIES

5 1/4" VALVE BOX DROP LID  
WITH 4" SKIRT

DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-18				