



## EM Johnson WTP Monthly Finished Water Quality Report April 2023

Parameter	Plant Tap	Primary MCL **	Secondary MCL **
Temperature, °C	18.8		
Color, units	0.0		<b>15</b>
pH, units	8.4		<b>6.5 - 8.5</b>
Free Carbon Dioxide, mg/l	0.20		
Total Alkalinity, mg/l as CaCO <sub>3</sub>	26.3		
Total Hardness, mg/l as CaCO <sub>3</sub>	28.9		
Total Dissolved Solids, mg/l	99		<b>500</b>
Specific Conductivity, uS/cm	203		
Iron, mg/l	<0.10		<b>0.3</b>
Manganese, mg/l	<0.01		<b>0.05</b>
Fluoride, mg/l	0.70	<b>4</b>	<b>2</b>
Chloride, mg/l	12.7		<b>250</b>
Ammonia, mg/l as N	0.39		
Nitrate, mg/l as N	0.07	<b>10</b>	
Silica, mg/l as SiO <sub>3</sub>	6.0		
Total Coliform Bacteria*	Absent	<b>0</b>	
E. Coli	Absent	<b>0</b>	
Total Trihalomethanes, mg/l	0.0196	<b>0.080</b>	

\* In 95% of samples collected

\*\*MCL = Maximum Contaminant Level

Certified By: *Martesa Webb*

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604

---

*Raleigh Water: Serving the people of Garner, Knightdale, Raleigh, Rolesville,  
Wake Forest, Wendell, and Zebulon areas.*

One Exchange Plaza Building | 1 Exchange Plaza | Suite 600 | Raleigh, North Carolina 27601  
City of Raleigh (mailing address) | Post Office Box 590 | Raleigh, North Carolina 27602-0590

## EM Johnson WTP Finished Water Quality Report 2023 Plant Tap Summary

Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Average
Temperature, °C	10.1	11.8	14.7	18.8									13.9
Color, units	0.0	1.0	0.5	0									0.4
pH, units	8.4	8.4	8.4	8.4									8.4
Free Carbon Dioxide, mg/l	0.24	0.24	0.23	0.2									0.23
Total Alkalinity, mg/l as CaCO <sub>3</sub>	30.0	30.7	28.6	26.3									28.9
Total Hardness, mg/l as CaCO <sub>3</sub>	27.8	29.3	28.9	28.9									28.7
Total Dissolved Solids, mg/l	103	109	104	99									104
Specific Conductivity, uS/cm	210	223	213	203									212
Iron, mg/l	<0.10	<0.10	<0.10	<0.10									<0.10
Manganese, mg/l	<0.01	<0.01	<0.01	<0.01									<0.01
Fluoride, mg/l	0.73	0.74	0.74	0.70									0.73
Chloride, mg/l	15.0	14.9	14.5	12.7									14.3
Ammonia, mg/l as N	0.52	0.47	***	0.39									0.5
Nitrate, mg/l as N	0.23	0.13	0.11	0.07									0.14
Silica, mg/l as SiO <sub>3</sub>	8.30	7.80	7.90	6.00									7.50
Total Coliform Bacteria	Absent	Absent	Absent	Absent									Absent
E. Coli	Absent	Absent	Absent	Absent									Absent
Total Trihalomethanes, mg/l	0.013	0.0057	0.0296	0.0196									0.0170

\*\*\*Chlorine Burnout, no ammonia added

Certified By: Martesa Webb

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604