



EM Johnson WTP Monthly Finished Water Quality Report September 2023

Parameter	Plant Tap	Primary MCL **	Secondary MCL **
Temperature, °C	26.9		
Color, units	0.0		15
pH, units	8.4		6.5 - 8.5
Free Carbon Dioxide, mg/l	0.27		
Total Alkalinity, mg/l as CaCO ₃	32.1		
Total Hardness, mg/l as CaCO ₃	26.1		
Total Dissolved Solids, mg/l	109		500
Specific Conductivity, uS/cm	223		
Iron, mg/l	<0.10		0.3
Manganese, mg/l	<0.01		0.05
Fluoride, mg/l	0.78	4	2
Chloride, mg/l	11.3		250
Ammonia, mg/l as N	0.59		
Nitrate, mg/l as N	0.05	10	
Silica, mg/l as SiO ₃	6.6		
Total Coliform Bacteria*	Absent	0	
E. Coli	Absent	0	
Total Trihalomethanes, mg/l	0.0249	0.080	

* In 95% of samples collected

**MCL = Maximum Contaminant Level

Certified By: *Martesa Webb*

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604

*Raleigh Water: Serving the people of Garner, Knightdale, Raleigh, Rolesville,
Wake Forest, Wendell, and Zebulon areas.*

One Exchange Plaza Building | 1 Exchange Plaza | Suite 600 | Raleigh, North Carolina 27601
City of Raleigh (mailing address) | Post Office Box 590 | Raleigh, North Carolina 27602-0590

EM Johnson WTP Finished Water Quality Report 2023 Plant Tap Summary

Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Average
Temperature, °C	10.1	11.8	14.7	18.8	21.8	24.7	29.2	29.4	26.9				20.8
Color, units	0.0	1.0	0.5	0.0	0.0	0.0	0	0	0				0.2
pH, units	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4				8.4
Free Carbon Dioxide, mg/l	0.24	0.24	0.23	0.20	0.23	0.21	0.23	0.23	0.27				0.23
Total Alkalinity, mg/l as CaCO ₃	30.0	30.7	28.6	26.3	26.6	27.5	28.1	28.9	32.1				28.8
Total Hardness, mg/l as CaCO ₃	27.8	29.3	28.9	28.9	25.3	28	26.7	26.7	26.1				27.5
Total Dissolved Solids, mg/l	103	109	104	99	94	96	94	105	109				101
Specific Conductivity, uS/cm	210	223	213	203	192	197	193	214	223				208
Iron, mg/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10				<0.10
Manganese, mg/l	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01				<0.01
Fluoride, mg/l	0.73	0.74	0.74	0.70	0.73	0.73	0.80	0.78	0.78				0.75
Chloride, mg/l	15.0	14.9	14.5	12.7	11.2	11.2	11.4	11.5	11.3				12.6
Ammonia, mg/l as N	0.52	0.47	***	0.39	0.55	0.53	0.74	0.91	0.59				0.6
Nitrate, mg/l as N	0.23	0.13	0.11	0.07	0.04	0.04	0.05	0.05	0.05				0.09
Silica, mg/l as SiO ₃	8.30	7.80	7.90	6.00	5.40	6.00	6.00	6.20	6.60				6.69
Total Coliform Bacteria	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent
E. Coli	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent
Total Trihalomethanes, mg/l	0.013	0.0057	0.0296	0.0196	0.0130	0.0155	0.0281	0.041	0.0249				0.0212

***Chlorine Burnout, no ammonia added

Certified By: Martesa Webb

Martesa Webb, Laboratory Scientist Supervisor

NC Lab ID Number 37604