CITY OF RALEIGH

2022 Perfluorinated Compounds Data Results

units: ng/L

		1/27/2022				4/27/2022				7/27/2022				10/17/2022				
		EMJWTP		DEBWTP		EMJWTP		DEBWTP		EMJWTP		DEBWTP		EMJWTP		DEBWTP		
Perfluorinated Compounds Contaminant	**EPA MRL**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Finished**	**Raw**	**Health Advisory Levels**
GenX	5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	10
Perfluorobutanesulfonic acid (PFBS)	3.0	**3.4**	**3.4**	<3.0	<3.0	**3.0**	**3.0**	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	2000
Perfluorooctanesulfonic acid (PFOS)	4.0	**5.1**	**5.3**	<4.0	<4.0	**4.8**	**4.5**	<4.0	<4.0	**4.4**	**4.6**	<4.0	**4.0**	**5.5**	**5.8**	<4.0	<4.0	0.02
Perfluorooctanoic acid (PFOA)	4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	0.004