

NOTES:

- I . IRRIGATION METER SHALL BE LOCATED ON THE SIDE OF DOMESTIC METER WITH INCREASING ADDRESSES.
- 2. THE BACKFLOW SHALL BE INSTALLED NO MORE THAN 50^{\prime} FROM THE METER IN A VISIBLE LOCATION.
- 3. BACKFLOW RISER/STANDPIPE SHALL BE OF COPPER OR BRASS.
- 3. THE RP RELIEF VALVE SHALL BE A MINIMUM OF 12" ABOVE ANY MATERIAL (MULCH INCLUDED) OR GRADE.
- 4. A SERVICE VALVE IS REQUIRED AFTER THE METER BUT BEFORE THE BACKFLOW ASSEMBLY FOR MAINTENANCE AND REPLACEMENT PURPOSES.
- 5. THE INSTALLATION MUST ALSO MEET ALL CODE REQUIREMENTS PER THE NC PLUMBING CODE.

		CITY OF RALEIGH				
		DEPARTMENT OF PUBLIC UTILITIES				
				AP ON NEW AND EXISTING SERVICES		
	DWG. NO.	REVISIONS	DATE	REVISIONS	DATE	
	W-35	RRH	3-31-00	D.H.L.	6-18-08	
		ABB	7-10-04	J.P.S.	10/25/10	