



PROPOSED PIPELINE UNDER EXISTING PIPE

PROPOSED PIPELINE OVER EXISTING PIPE

NOTE:  
 NO ENCASEMENT REQUIRED FOR SPACE  
 GREATER THAN 18" FOR WATER LINES.

<b>CITY OF RALEIGH</b>		
<b>STANDARD DETAIL</b>		
REVISIONS	DATE: 01/18/2025	NOT TO SCALE
	CONCRETE CRADLE PROTECTION FOR WATER LINE CROSSINGS	
	<b>W-41</b>	