



EM Johnson WTP Monthly Finished Water Quality Report July 2026

Parameter	Plant Tap	Primary MCL **	Secondary MCL **
Temperature, °C	30.4		
Color, units	0.0		15
pH, units	8.38		6.5 - 8.5
Free Carbon Dioxide, mg/l	0.27		
Total Alkalinity, mg/l as CaCO ₃	30.2		
Total Hardness, mg/l as CaCO ₃	29.7		
Specific Conductivity, uS/cm	221		
Iron, mg/l	<0.10		0.3
Manganese, mg/l	<0.01		0.05
Fluoride, mg/l	0.54	4	2
Chloride, mg/l	19.8		250
Ammonia, mg/l as N	0.560		
Nitrate, mg/l as N	0.09	10	
Silica, mg/l as SiO ₃	2.99		
Total Coliform Bacteria*	Absent	0	
E. Coli	Absent	0	
Total Trihalomethanes, mg/l	0.029	0.080	

* In 95% of samples collected

**MCL = Maximum Contaminant Level

Certified By: Martesa Webb
Martesa Webb, Laboratory Manager
NC Lab ID Number 37604

*Raleigh Water: Serving the people of Garner, Knightdale, Raleigh, Rolesville,
Wake Forest, Wendell, and Zebulon areas.*

One Exchange Plaza Building | 1 Exchange Plaza | Suite 600 | Raleigh, North Carolina 27601
City of Raleigh (mailing address) | Post Office Box 590 | Raleigh, North Carolina 27602-0590

EM Johnson WTP Finished Water Quality Report 2026 Plant Tap Summary

Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Average
Temperature, °C	13.3	9.0	12.3	16.5	19.5	28.7	30.4						18.5
Color, units	0.50	2.0	0.0	0.0	0.3	0.0	0.0						0.4
pH, units	8.36	8.33	8.4	8.3	8.3	8.3	8.4						8.3
Free Carbon Dioxide, mg/l	0.19	0.2	0.20	0.22	0.24	0.27	0.27						0.23
Total Alkalinity, mg/l as CaCO ₃	21.5	20.2	22.4	23.8	25.7	27.4	30.2						24.5
Total Hardness, mg/l as CaCO ₃	22.0	23.6	23.5	25.3	27.5	29.2	29.7						25.8
Specific Conductivity, uS/cm	170	168	173	182	192	209	221						188
Iron, mg/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10						<0.10
Manganese, mg/l	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01						<0.01
Fluoride, mg/l	0.65	0.64	0.65	0.66	0.67	0.54	0.54						0.62
Chloride, mg/l	9.84	10.2	11.2	12.1	14.2	16.9	19.8						13.5
Ammonia, mg/l as N	0.49	0.43	0.05***	0.64	0.49	0.53	0.56						0.52
Nitrate, mg/l as N	0.20	0.14	0.15	0.10	0.09	0.05	0.09						0.12
Silica, mg/l as SiO ₃	9.40	8.76	7.80	5.15	3.45	2.78	2.99						5.76
Total Coliform Bacteria	Absent	Absent	Absent	Absent	Absent	Absent	Absent						Absent
E. Coli	Absent	Absent	Absent	Absent	Absent	Absent	Absent						Absent
Total Trihalomethanes, mg/l	0.0156	0.0112	0.011	0.013	0.016	0.025	0.029						0.017

Certified By: Martesa Webb

Martesa Webb, Laboratory Manager

NC Lab ID Number 37604